

Safety Notes

for Safe Installation and Use

Important information on the safe installation and use of our products

The connecting component is for universal use in lightning protection systems in accordance with DIN EN 62305 (VDE 0185-305). It connects different conductor materials in earthing systems and interception directions and is suitable for indoor and outdoor areas. In the ground, it must be wrapped with a corrosion protection bandage (article no.: [1018](#)). Technical data and application examples from the instructions must be observed.

Qualified specialist personnel

Installation work may only be carried out by qualified and trained specialist personnel.

Compliance with the specifications

Installation is only permitted within the framework of the specifications and conditions stated in the corresponding installation instructions.

Checking the components

Before installation, all connecting components must be checked for proper condition. Damaged or defective components must not be used.

Cleaning in case of contamination

Contaminated components must be cleaned before installation to ensure an optimum contact surface.

Material combinations and clamping ranges

Only approved material combinations and clamping ranges according to the product data sheet may be used to ensure permanent conductivity.

Observe the tightening torques

Depending on the screw size, the tightening torques specified in the instructions must be observed.

Safety interruption during thunderstorms

For safety reasons, installation work must be interrupted immediately if thunderstorms are detected or approaching.

Personal protective equipment

We recommend wearing personal protective equipment during installation work.